

Tokens for ProfiLux 3 & 4

Tokens are placeholders in emails or web pages which are filled with actual values when an email or a web page is transmitted. The use of tokens makes it quite easy to generate content with live data.

Only for ProfiLux 3 web server:

The ProfiLux main page *index.html* provides a link *user web page*, this links to the file *user.html*. It is easy to integrate this user file in the ProfiLux 3 web server:

1. Create a file *user.html*
2. Upload this file with TFTP to the ProfiLux 3

It is possible to upload several files, these files may link to each other. ProfiLux 3 offers 256 kB space for user files.

Using ProfiLux-specific tokens

Webserver content (ProfiLux 3 only)

ProfiLux scans the requested file when it has a certain file extension (only *.html, *.rss and *.xml are scanned, all other file types are passed through unmodified!) for these tokens and replaces them with live data. The parsing of a file takes some time, if your HTML-file doesn't have any tokens which have to be evaluated then use the file extension *.htm, these files will not be scanned and the output will be faster.

Email content (ProfiLux 3 and 4)

ProfiLux scans the email and replaces found tokens with live data.

List of tokens

Token	Returns	Minimum firmware P3	Minimum firmware P4
\$\$SENC[n]\$\$	Complete name, actual value and state of sensor <i>n</i>		7.00
\$\$SENL[n]\$\$	Complete name, actual value and state of sensor <i>n</i> . long (incl. description)	5.08	7.00
\$\$SENV[n]\$\$	Actual value of sensor <i>n</i> returns "---" if this sensor is disabled		7.00
\$\$SENN[n]\$\$	Name of sensor <i>n</i>		7.00
\$\$SENS[n]\$\$	Short name of sensor <i>n</i>		7.00
\$\$SEND[n]\$\$	Description of sensor <i>n</i> (not supported for KHD)	5.08	7.00
\$\$SENT[n]\$\$	Type of sensor <i>n</i> as numerical value 0 = none, 1 = temp., 2 = pH, 3 = redox, 4 = cond. Freshwater, 5 = cond. Saltwater, 6 = none, 7 = humidity, 8 = airtemp., 9 = oxygen, 10 = voltage, 100 = KHD	5.09	7.00
\$\$SENX[n]\$\$	Nominal value of sensor <i>n</i>	5.09	7.00
\$\$SENF[n]\$\$	Format of nominal and actual value of sensor <i>n</i>	5.15	7.00

	Returns <i>int:dec:unit</i> , where <i>int</i> is max. number of digits before the decimalpoint <i>dec</i> is the number of digits after the decimalpoint <i>unit</i> is the unit for this sensor		
\$\$SENO[n]\$\$	Operation state of sensor <i>n</i> : “+” = control upwards “-” = control downwards “*” = cooling (only for temp. sensor) “#” = main heater (only for temp. sensor) “~” = bottom heater (only for temp. sensor) “!” = alarm (not supported for KHD)	5.15	7.00
\$\$SENR[n]\$\$	Nominal value range of sensor <i>n</i> Return <i>max...min</i> , where <i>min</i> is the minimal allowed value and <i>max</i> is the maximal allowed value both without unit (not supported for KHD)	5.15	7.00
\$\$LEV[n]\$\$	Value of level sensor <i>n</i>		7.00
\$\$LEVN[n]\$\$	Name of level sensor <i>n</i>		7.00
\$\$ILLC[n]\$\$	Complete name and value of illumination <i>n</i>		7.00
\$\$ILLL[n]\$\$	Complete state of illumination <i>n</i> long (incl. description)	5.08	7.00
\$\$ILLV[n]\$\$	Value of illumination <i>n</i>		7.00
\$\$ILLN[n]\$\$	Name of illumination <i>n</i>		7.00
\$\$ILLD[n]\$\$	Description of illumination <i>n</i>	5.08	7.00
\$\$ILLP[n]\$\$	Properties of illumination <i>n</i> “d” = dimmable “u” = used (has dimming points)	5.15	7.00
\$\$ILCL[n]\$\$	Color of illumination <i>n</i>	6.08	7.00
\$\$PROM\$\$	ProfiLux model name		7.00
\$\$FWV\$\$	Firmware version		7.00
\$\$FWDA\$\$	Firmware date		7.00
\$\$SERI\$\$	Serial number		7.00
\$\$SWIS[n]\$\$	State of switch output <i>n</i> : “off” = off “on” = on		7.00
\$\$SWIV[n]\$\$	State of switch output <i>n</i> : “0” = off “1” = on		7.00
\$\$SWIN[n]\$\$	Name of switch output <i>n</i>		7.00
\$\$SWID[n]\$\$	Description of switch output <i>n</i>	5.09	7.00
\$\$SWIP[n]\$\$	Properties of switch output <i>n</i> “u” = used (has other function than <i>always off</i>)	5.15	7.00
\$\$SWIM[n]\$\$	Switch operation mode “1” = manual “0” = auto	6.06	7.00
\$\$DATE\$\$	Current date in ProfiLux		7.00

\$\$TIME\$\$	Current time in ProfiLux		7.00
\$\$GCOV[n]\$\$	Get code value – returns a string with the value(raw data) of any parameter (code) <i>n</i> of the ProfiLux		7.00
\$\$GWBS[n]\$\$	Get web string – returns a string which can be used for creating multi language pages		7.00
\$\$ALMS\$\$	Current alarm state, if there are several alarms active the alarm sources will be displayed alternating with each invoke of this token		7.00
\$\$ALMS[n]\$\$	Current alarm state, <i>n</i> determines which alarm source should be displayed Since it is unknown if and how many alarms are active the use of the indexed alarm-token makes only sense if used in a loop, see example below	5.05e	7.00
\$\$AMSE\$\$	Alarm mask all sensors	5.16	7.00
\$\$AMLC\$\$	Alarm mask all level controls	5.16	7.00
\$\$AMMI\$\$	Alarm mask miscellaneous (Bits 11-8: flow sensors, Bit 0: PAB-alarm)	5.16	7.00
\$\$TDRS\$\$	Current time and date for RSS feed		7.00
\$\$EXWA\$\$	External web address of ProfiLux		7.00
\$\$OTVI[n]\$\$	Actual output voltage of 1-10V-interface <i>n</i>	5.04	7.00
\$\$SWIC[n]\$\$	Actual current of switch output <i>n</i>	5.05f	7.00
\$\$LVCN[n]\$\$	Name of level control <i>n</i>	5.15	7.00
\$\$LVCD[n]\$\$	Description of level control <i>n</i>	5.15	7.00
\$\$LVCO[n]\$\$	Operation state of level control <i>n</i> : “+” = fill water “-” = drain water “!” = alarm “1” = first level sensor of this control indicates contact “2” = second level sensor of this control indicates contact (if present)	5.15	7.00
\$\$LANG\$\$	Returns the language ProfiLux is using, e.g.: “Deutsch” “English” “Espanol” “Francais”		7.00
\$\$FPSN[n]\$\$	Name of feedpause <i>n</i>	5.15	7.00
\$\$FPSD[n]\$\$	Description of feedpause <i>n</i>	5.15	7.00
\$\$FPSR[n]\$\$	Remaining time for feedpause <i>n</i> “0 s” means this feedpause is not active	5.15	7.00
\$\$MAIN[n]\$\$	Name of maintenance <i>n</i>	5.15	7.00
\$\$MAID[n]\$\$	Description of maintenance <i>n</i>	5.15	7.00
\$\$MAIR[n]\$\$	Remaining time for maintenance <i>n</i> “0 s” means this maintenance is not active	5.15	7.00
\$\$AWCN[n]\$\$	Name of automatic waterchange <i>n</i>	5.15	7.00
\$\$AWCS[n]\$\$	State of automatic waterchange <i>n</i> : “+” = fill water “-” = drain water “!” = alarm	5.15	7.00

	otherwise idle		
\$\$THSS\$\$	State of thunderstorm: "0" = no thunderstorm "1" = thunderstorm in progress	5.15	7.00
\$\$MEAS[n]\$\$	Measurement value sample <i>n</i> This returns a sample of a certain sensor, the index of the sensor is determined by the suffix of the loaded file, e.g. sensordata003.txt returns values of sensor 3. Index <i>n</i> = 0 returns the newest sample. The format is: <i>yyyy-mm-dd hh:mm value</i> , where <i>yyyy-mm-dd</i> is the date (year, month, day) <i>hh:mm</i> is the time (hours, minutes) <i>value</i> is the measured value with unit, e.g.: 2012-12-10 16:07 21.300 C This token is usually used in a loop, see example below. In order to retrieve only samples until a certain time and date the code	5.15	7.00
\$\$EHMF\$\$	Actual flow of EHEIM filter in litres/hour, "---" if no EHEIM filter is present	5.16	7.00
\$\$EHMS\$\$	Time to next service for EHEIM filter in hours, "--" if no EHEIM filter is present	5.16	7.00
\$\$FLSV[n]\$\$	Actual value of flow sensor <i>n</i> returns "---" if this sensor is disabled	5.17	7.00
\$\$FLSN[n]\$\$	Name of flow sensor <i>n</i>	5.17	7.00
\$\$FLSF[n]\$\$	Format of nominal and actual value of sensor <i>n</i> Returns <i>int:dec:unit</i> , where <i>int</i> is max. number of digits before the decimalpoint <i>dec</i> is the number of digits after the decimalpoint <i>unit</i> is the unit for this sensor	5.17	7.00
\$\$FLSD[n]\$\$	Description of flow sensor <i>n</i>	5.17	7.00
\$\$RMDT\$\$	Text of first active reminder	5.17	7.00
\$\$RMDT[n]\$\$	Text of reminder <i>n</i> , if it is active	5.17	7.00
\$\$RMDP[n]\$\$	Reminder properties "m" = multiple reminder	6.06	7.00
\$\$RMDD[n]\$\$	Days count until reminder <i>n</i> is shown	6.06	7.00
\$\$DOSN[n]\$\$	Name of doser <i>n</i>	6.08	7.00
\$\$DOSL[n]\$\$	Last for days doser <i>n</i>	6.08	7.00
\$\$DOSF[n]\$\$	Filling level of doser <i>n</i>	6.08	7.00
\$\$DOST[n]\$\$	Alarm threshold of doser <i>n</i>	6.08	7.00
\$\$DOSS[n]\$\$	State of doser <i>n</i>	6.08	7.00
\$\$DOSC[n]\$\$	Capacity of doser <i>n</i>	6.08	7.00
\$\$DOSD[n]\$\$	Description of doser <i>n</i>	6.08	7.00

Some tokens are indexed; in this case you have to replace n with the number of the resource you are going to access. Indexes start at 0.

Most sensor tokens (they start with “SEN”) can also be used for the KH Director, see notes which sensor tokens don’t work with the KHD.

Special indices:

- ¶ If you write “x” for the index then this index will be replaced with the current loop counter, see tokens for creating a loop below.
- ¶ With “k” as index you access the values and states of the KH director (if present)
- ¶ Files of the webserver may have a trailing index in the filename, e.g. “MyFile003.html”. With “f” as index the internal index will be overwritten with the current index found in the file name, in this example “3”.

Examples:

Email or web content	Result
My sensor: \$\$SENN[0]\$\$	My sensor: pH 1 (assuming the first sensor is a pH-sensor)
My ProfiLux is a \$\$PROM\$\$	My ProfiLux is a ProfiLux 3 eX (if it is an e7.00X-version)
Firmware: \$\$GCOV[0]\$\$	Firmware: 500 (Code 0 returns the firmware version)
Sensor value of this page: \$\$SENV[f]\$\$	Assumed the filename was “mysensor002.html”, the output is the value of sensor 2

Furthermore there are tokens for creating a loop:

Token	Meaning
\$\$REPS[c][o]\$\$	<i>Repeat Start</i> , c = count of repeats, o = option, following code until \$\$REPE\$\$ will be repeated c times [o] is optional
\$\$REPE\$\$	<i>Repeat End</i>
\$\$LCTR\$\$	Returns current value of the internal counter during executing the loops.

The content between these 2 tokens will be repeated c times, an internal counter will be counted from 0 to $c-1$. This internal counter can be accessed with the “index” x .

The option o determines if the loop shall be executed depending on the presence or activation of a resource (= sensor, illumination channel, switch output, ...). If [o] is not mentioned then all loops will be executed, if [o] is mentioned then o can have these values:

Value for the option o	Will check presence or activity of this resource:
0	Sensor
1	Illumination

2	Switch output
3	Level-Sensor
4	1-10V-Interface
5	Alarm (ProfiLux firmware 5.05e or higher required)
6	Level control
7	Feedpause
8	Maintenance
9	Waterchange
10	Flow-Sensor
11	Reminder

Hiding text depending on the current login status:

Token	Meaning
\$\$IFLS[n]\$\$	<i>If Logged in Start</i> , the following text until token <i>\$\$IFLE\$\$</i> will only be shown if the login privileges are at least <i>n</i> : 1: Guest or Admin must be logged in 2: Admin must be logged in
\$\$IFLE\$\$	<i>If Logged in End</i>

Examples:

HTML-code	Result
<pre> \$\$REPS[3]\$\$ <p>My sensor: \$\$SENN[x]\$\$</p> \$\$REPE\$\$ </pre>	My sensor: pH 1 My sensor: Temp 1 My sensor: Redx 1 (assuming these sensor input were present)
<pre> \$\$REPS[32][1]\$\$ <p>\$\$ILLN[x]\$\$... \$\$ILLV[x]\$\$</p> \$\$REPE\$\$ </pre>	Illumina. 1 ... 100% Illumina. 2 ... 79% Illumina. 3 ... 0% (if only illumination channels 1-3 are active)
<pre> \$\$REPS[10][5]\$\$ <p>\$\$ALMS[x]\$\$</p> \$\$REPE\$\$ </pre>	list all alarms, e.g.: Alarm: p H 2 Alarm: Temp 2 Alarm: Le.F 1

In the second example the loop runs from 0 to 31 (32 times), but a loop only produces an output if the resource (here: illumination) is activated.